Performance standards for type of discharge using TN and TP

Project Scenario	TP	TN	Additional Criteria
All Sites exceptions follow	80	55	or Post<=Pre
OFW	90	80	or Post<=Pre
Impaired Water	80	80	& Post<=Pre
Impaired + OFW	95	95	& Post<=Pre
Redevelopment	80	45	none
Redevelopment + OFW	90	60	none
Redevelopment + IMP	80	45	and pollutant of concern
Specified Removal			
Post<=Pre			
BMP			

Ref: Applicants Handbook Vol 1 Section 8.3 State of Florida, 2024